

DIPL.-BIOL. DR. RER. NAT. FLORIAN H. H. BRILL

C/O DR. BRILL + PARTNER GMBH

INSTITUT FÜR HYGIENE UND MIKROBIOLOGIE

STIEGSTÜCK 34, DE-22339 HAMBURG

TELEFON 0049-40/557631-0

TELEFAX 0049-40/557631-11

EMAIL INFO@BRILLHYGIENE.COM

INTERNET WWW.BRILLHYGIENE.COM

DR. F. H. H. BRILL · C/O DR. BRILL + PARTNER GMBH · STIEGSTÜCK 34 · DE-22339 HAMBURG

Danish Clean Water A/S  
Nordborgvej 81L21, N12  
DK – 6430 Nordborg

Hamburg, 10 February 2015

## Expert opinion

### Bactericidal Activity of **Neuthox** in the Quantitative Suspension Test against *Legionella* according to DIN EN 13623:2010 (Phase 2, Step 1)

The disinfectant **Neuthox** was tested and evaluated according to DIN EN 13623:2010 "Chemical disinfectants and antisepsics - Quantitative suspension test for the evaluation of bactericidal activity against *Legionella* of chemical disinfectants for aqueous systems – Test method and requirements (phase 2, step 1)".

According to the test report no. L15/0053.2 dated 10/02/2015 of Dr. Brill + Partner GmbH the preparation showed bactericidal activity with 0.0005 % Yeast extract under conditions for water for general purpose (hard water for general purpose (HWGP, pH 7.2) and 20°C ± 1°C).

**Neuthox** complies with the requirements of DIN EN 13623:2010 (phase 2, step 1) with the following concentration-time relationship:

<b>water for general purpose</b>	0.0005 % Yeast extract	<b>3 ppm</b>	<b>60 minutes</b>
----------------------------------	------------------------	--------------	-------------------



Dr. Florian H. H. Brill